



CITY OF BLOOMINGTON
Fire Prevention Division

STATEMENT OF POLICY

Policy #: BFP-0008	Wet Kitchen Hood Systems in the Remote Area		
Reviewed and Approved By: Gene Dugal	Title: Fire Marshal	Effective Date: September 1, 2008	Revised Date:

PURPOSE:

The purpose of this policy is to clarify the fire sprinkler design parameters when a wet kitchen hood system falls within a hydraulically remote design area.

POLICY:

When kitchen hoods are located in a hydraulically remote area of a sprinkled building, the remote area must be expanded to include the required size (typically 1,500 sq. ft.) plus the additional flow and pressure required by the hood's extinguishing system.